## INDOOR / INDUSTRIAL / DRACO LINEAR / DRACO LINEAR

## Item code 86.1006.2451.02






- Installation and wiring of luminaire must be in accordance with all applicable local codes.
- Installation, inspection, and maintenance of luminaires should be performed by a qualified
- electrician.
- DO NOT make or alter any open holes in the luminaire. Do not modify the luminaire.
- DO NOT install damaged product.
- Make sure electrical power is OFF before and during installation and maintenance.
- Make sure the equipment is properly grounded.
- Make sure the supply voltage is same as the rated fixture voltage.




## INDOOR / INDUSTRIAL / DRACO LINEAR / DRACO LINEAR



1. Take out the high bay light and put up-right, and then check to make sure the lamp bodyis all right.



2. **Suspended Installation**: Making clasp, rings and lifting rope fixed successively on high bay and then hanging the other end of lifting rope in right place like below picture.



NOTE:

The distance between the two holes in the ceiling, recommended range.



Item	Y
100W High Bay Light	645±5mm
150W High Bay Light	955±5mm
200W High Bay Light	1260±5mm

3. Make connection with mains supply as per following instruction and light up.

