INDOOR / INDUSTRIAL / DRACO LINEAR / DRACO LINEAR SMART

Item code 86.IST6.3459.02






- Installation and wiring of luminaire must be in accordance with all applicable local codes.
- Installation, inspection, and maintenance of luminaires should be performed by a qualified electrician.
- DO NOT make or alter any open holes in the luminaire. Do not modify the luminaire.
- DO NOT install damaged product.
- Make sure electrical power is OFF before and during installation and maintenance.
- Make sure the equipment is properly grounded.
- Make sure the supply voltage is same as the rated fixture voltage.






1. Take out the high bay light and put up-right, and then check to make sure the lamp bodyis all right.



2. Suspended Installation: Making clasp, rings and lifting rope fixed successively on high bay and then hanging the other end of lifting rope in right place like below picture.



The distance between the two holes in the ceiling, recommended range.



Item	Y
100W High Bay Light	645±5mm
150W High Bay Light	955±5mm
200W High Bay Light	1260±5mm

3. Make connection with mains supply as per following instruction and light up.

